

## MANIFOLD #100 (NOT FOR USE WITH R410 SYSTEMS)

- 1. Remove contents from package
- 2. Shut off manifold on/off valve before making any connections of hoses or a/c equipment
- 3. Connect hose ends, without depressor, to manifold
- 4. End of hoses with depressor go to a/c and product connections
- Hose attached to manifold coming out of bottom with depressor is connected to a/c service port
- 6. Hose attached to manifold on side of gauge is attached to product refrigerant
- 7. Use shut off valve on manifold to regulate refrigerant flow
- 8. When shut off valve is closed you will read the a/c pressure of a/c
- 9. When valve is open you will be inserting refrigerant into system

NOTE: To be used by professional personnel only. Always follow manufacturer's specifications. Always wear your Personal Protective Equipment when servicing any a/c. Refrigerant is very cold and may cause frost bite.

Telephone: 309-346-1110; Fax: 309-346-1237

http://www.es-refrigerants.com