

# ENVIRO-SAFE



## REFRIGERANTS

### MANIFOLD #200 (NOT FOR USE WITH R410 SYSTEMS)

1. Remove contents from package
2. Shut off manifold on/off valve before making any connections of hoses or a/c equipment
3. Connect hose ends, without depressor, to manifold
4. End of hoses with depressor go to a/c and product connections
5. Short hose attached to manifold other end to can tap. This hose will only connect one way. Large end to can tap, small end to manifold.
6. Hose attached to manifold on side of gauge is attached to product refrigerant
7. Use shut off valve on manifold to regulate refrigerant flow
8. When shut off valve is closed you will read the a/c pressure of a/c
9. When valve is open you will be inserting refrigerant into system

NOTE: To be used by professional personnel only. Always follow manufacturer's specifications. Always wear your Personal Protective Equipment when servicing any a/c. Refrigerant is very cold and may cause frost bite.